



## MURRAY CITY POWER DEPARTMENT

Call out procedure for Water System Shutdowns:

During the irrigation season, **April 15<sup>th</sup> thru October 15<sup>th</sup>** any water system shutdowns should be considered a top priority in contacting irrigation water users that are affected by loss of water through the penstock. All Planned maintenance that would close the water through the penstock please contact the Little Cottonwood Commissioners prior to shutdown.

Water System Shutdown contact the following:

1) Contact the Little Cottonwood Commissioners:

Marv Widerberg

Tim O'Hara 483-6784

2) Contact the following

### **Richards Ditch Company**

Contact: Marv Widerberg

They receive their water from the output of the Hydro Plant, contact them on all water system shutdown, they are most critical when we are not spilling water. A prolonged water system shutdown that cannot be reset from an equipment failure, loss of level detection or other. Instruct the Substation Tech on-call to open the needle valve manually and allow water to flow through the plant. If this is done the Substation Tech must insure that he does not allow the penstock to drain!

### **South Despain Extension**

Contact Ron Vance

During a water system shutdown they are adversely affected by a large flow increase that clog the intake for South Despain with debris. They must be given **prior** notice before any Murray intake maintenance work that would cause a sudden, large release of water into the stream.